

<b>INDIAN REGISTER OF SHIPPING</b>	<b>INSPECTION REPORT</b>	Survey Station: Kolkata
		Stage / Final: Stage
		Date : 19/04/2018

Report No:	KOL/SPT/1904/01		
Vendor :	M/s. Paharpur Cooling Towers Ltd / Sub Vendor: ARC Insulation & Insulators Pvt. Ltd.	Location : Bawali, West Bengal	
Client/Project:	M/s. ITER – India, CWS Project.		
P. O. No & Date :	EA482PO7000106 & EA482PO7000107 Dated : 04.10.2017		
Mode of Inspection Request (Verbal / Email / Fax):	Email-18.04.2018(Call no PCT/ITER/Header pipe/01, Dt:18.04.2018 )		
Tech. Spec. No.	O13188-M-CT-CW-DA-1308		
Drawing No.	O13188-M-CT-CW-GA-XXXX	Rev. no. 03	Date:
QAP /ITP/MIP Ref. No.:	PCTL/L&T/ITER/MIP-01	Rev. no. 04	Date: 21.12.2016
Previous visit report Ref. No. & Date:			
Pending observations in previous report (if any): NIL			

Inspection Details:

SR.NO.	ITEM DESCRIPTION	MIP Clause No	OFFERED QTY.	REMARKS
01	HOT WATER DISTRIBUTION HEADER PIPE PART NO:14-210028/F/04-01, 14-210028/F/04-02 & Vent Pipe	2.5.4 (a, b)	6 Nos (For 06 cells)	

- Verified Availability Of Approved MIP. Found In Order.
- Header pipe visual & dimension check found satisfactory.
- Review of raw material test certificate and internal inspection report found satisfactory.
- Protective coating (resin coat) to be provided on pipes and report to be submitted prior to packing inspection.
- For the purpose of identification pipe provide with sticker stamp thus







Remarks :

Calibration Status of Instruments used : Found valid calibration  
(Mention Sr. No., Verify Traceability as per National / International Standard)

Reports of Calibration of Inst. Verified : (Attach Reports for Reference as Applicable)	Yes	No
--	-----	----

Conclusion (Accepted / Not Accepted / Hold): Cleared for next stage

Remarks (if Not Accepted / Hold):

  SIBA PASAD TIPIRAJ Name & Sign of Surveyor (s)	  Name & Sign of Vendor Rep.	
		Travel Time to Job :

19/4/18  
PCTC

Minutes of meeting

Minutes of meeting held at M/s ARC Insulation & Insulators Pvt. Ltd. , Bawali, West Bengal on 19.04.2018 for ITER-India CWS Project. The following were present:

INDIAN REGISTER OF SHIPPING	M/s L&T LTD.	M/S. PAHARPUR COOLING TOWERS LTD	M/s ARC Insulation & Insulators Pvt. Ltd.
Mr. S.P.TIPIRIA	Mr. SOUMEN CHATTERJEE	Mr. R.P.PANDEY	Mr. SUBHADIP ROY Mr. RAJESH REDDY

Client: M/S ITER-India.

Project: ITER- CWS Project

P. O. No & Date: PO no: EA482PO7000106 & EA482PO7000107 Dated : 04/10/2017

Ref MIP No: PCTL/L&T/ITER/MIP-01, Rev-04, Dated : 21.12.2016

As per inspection call (Call no PCT/ITER/Header pipe/01, Dt:18.04.2018) from M/S Paharpur Cooling Towers Ltd. IRS(QS) & L&T have visited M/S ARC Insulation & Insulators Pvt. Ltd., Bawali, West Bengal on 19.04.2018 to carry out inspection of below mentioned materials .

Inspection Details:

SR.NO.	ITEM DESCRIPTION	MIP Clause No	OFFERED QTY.	REMARKS
01	HOT WATER DISTRIBUTION HEADER PIPE PART NO:14-210028/F/04-01, 14-210028/F/04-02 & Vent Pipe	2.5.4 (a, b)	06 sets (For 06 cells)	

- Verified Availability Of Approved MIP. Found In Order.
- Header pipe visual & dimension check found satisfactory.
- Review of raw material test certificate and internal inspection report found satisfactory.
- Protective coating (resin coat) to be provided on pipes and report to be submitted prior to packing inspection.



PCTL 19/4/18



ARC Insulation & Insulators  
Pvt. Ltd.